



**COUNTY OF RIVERSIDE  
DEPARTMENT OF ENVIRONMENTAL HEALTH**

(888)722-4234 • RIVCOEH.ORG

**INSPECTION REPORT**

FACILITY NAME Wendy's #12264				DATE 07/09/2024	TIME IN 12:45 PM	TIME OUT 01:30 PM
FACILITY ADDRESS 27251 Newport Rd Menifee, CA 92584-2400				FACILITY PHONE # (949) 858-9191		
PERMIT HOLDER Cotti Foods California Inc				EMAIL wcap@cottifoods.com		
RECORD # PR0082796	DESCRIPTION Restaurant 2001 to 5999	EXPIRATION DATE 09/30/2025	SPECIALIST NAME Kristen Burnham	DISTRICT 45	SERVICE Follow Up Inspection	REINSPECTION DATE Next Routine

**General Comments:**

The grease interceptor has been pumped. The inlet and outlet lines of the grease interceptor were hydro-jetted. Six floor sink drains and four floor drains were also hydro-jetted. The area of the overflow spill outside has been steam cleaned. Documentary evidence of these actions were emailed to K. Burnham at 12:11 am on 7-9-24. The facility was granted permission to resume operation at that time.

Follow up check at the facility:

Drains were observed to be functioning as designed. No overflow is occurring at the outside grease interceptor lids. The ground appears to be free of spilled grease and waste residue. No further rechecks are pending.

Be advised that in event of future grease interceptor failure, you must fully close the facility. All operation, including use of plumbing fixtures, must cease until the grease interceptor is restored to full function and the ground professionally cleaned. Failure to close during a future grease interceptor failure event will result in further legal action, including citation, Administrative Hearing, or suspension of the permit to operate.

**Observations:**

SIGNATURE	
PERSON IN CHARGE: <u>Jeydi Estrada</u> PRINT	INSPECTOR: <u>Kristen Burnham</u> PRINT