



**COUNTY OF RIVERSIDE**  
**DEPARTMENT OF ENVIRONMENTAL HEALTH**

(888)722-4234 • RIVCOEH.ORG

**INSPECTION REPORT**

FACILITY NAME Chipotle				DATE 11/08/2024	TIME IN 10:15 AM	TIME OUT 11:15 AM
FACILITY ADDRESS 8956 Trautwein Rd Ste 100 Riverside, CA 92508-9190				FACILITY PHONE # (402) 895-0878		
PERMIT HOLDER Chipotle Mexican Grill Inc				EMAIL licensing@chipotle.com		
RECORD # PR0065593	DESCRIPTION Restaurant 1 to 2000 sq ft	EXPIRATION DATE 09/30/2025	SPECIALIST NAME Esteban Delgado	DISTRICT 6	SERVICE Follow Up Inspection	REINSPECTION DATE 11/12/2024

**General Comments:**

Observed the following hot water temperatures:

- 119 F for the handwashing station by the cash register
- 119 F for the handwashing station by the cookline
- 110 F for the prep sink

Also observed the 3-compartment sink hot water at 99.9 F and mop sink hot water at 109.2 F. Observed the hot water at the prep sink, 3-compartment sink, and handwashing sink by the 3-compartment sink to reduce in hot water temperature when at least two sinks were on simultaneously to as low as 96 F for the prep sink. Ensure hot water at the 3-compartment sink and mop sink are at 120 F minimum. Re-inspection is set for 11/12/2024 to check hot water temperatures.

**Observations:**

**21. Hot and cold water available**

**Status:** OUT

**Type:** Violation



**Violation Code** - An adequate, protected, pressurized, potable supply of hot water and cold water shall be provided at all times. Hot water of at least 120°F must be provided for facilities with unpackaged food. Handwashing facilities shall be equipped to provide warm water for at least 15 seconds. (113953(c), 114189, 114192 (a,d), 114192.1, 114195)

**34. Utensils and equipment approved, good repair**

**Status:** OUT

**Type:** Violation

**Violation Code** - All utensils and equipment shall be approved and in good repair. (114130, 114130.1-114130.6, 114132, 114133, 114137, 114175, 114177, 114257)

SIGNATURE	
	
PERSON IN CHARGE: <u>Najette Brunson</u>	INSPECTOR: <u>Esteban Delgado</u>
PRINT	PRINT