



COUNTY OF RIVERSIDE DEPARTMENT OF ENVIRONMENTAL HEALTH

(888)722-4234 • RIVCOEH.ORG

INSPECTION REPORT

FACILITY NAME Chipotle				DATE 11/13/2024	TIME IN 12:00 AM	TIME OUT 01:00 PM
FACILITY ADDRESS 8956 Trautwein Rd Ste 100 Riverside, CA 92508-9190				FACILITY PHONE # (402) 895-0878		
PERMIT HOLDER Chipotle Mexican Grill Inc				EMAIL licensing@chipotle.com		
RECORD # PR0065593	DESCRIPTION Restaurant 1 to 2000 sq ft	EXPIRATION DATE 09/30/2025	SPECIALIST NAME Heidi Barrios	DISTRICT 6	SERVICE Follow Up Inspection	REINSPECTION DATE 11/14/2024

General Comments:

On 11/13/24, H. Barrios conducted a follow up inspection, following the initial food facility inspection on 11/7/24. Operator has restored function to the dish machine, it is observed to be dispensing chlorine at 50 ppm. Impound tag removed, facility authorized to use this unit.

The operator does not have a water heater service order. Unable to verify if the 2 Navien tankless, gas water heaters are installed in parallel and are properly functioning. Observed one unit flashing an error code. The water fluctuations still persist, throughout the facility as different water fixtures are in use.

Operator shall immediately order a plumbing diagnosis, repair and determine if these units are install in parallel, so that they function at the same time.

Send work order and compliance photos to hbarrios@rivco.org by 11/14/24.

Observations:

21. Hot and cold water available

Status: OUT

Type: Violation

Inspector Comments: See general comments

Violation Code - An adequate, protected, pressurized, potable supply of hot water and cold water shall be provided at all times. Hot water of at least 120°F must be provided for facilities with unpackaged food. Handwashing facilities shall be equipped to provide warm water for at least 15 seconds. (113953(c), 114189, 114192 (a,d), 114192.1, 114195)

Correct By Date: 11/14/2024

SIGNATURE	
PERSON IN CHARGE: <u>Abigail Welsh</u>	INSPECTOR: <u>Heidi Barrios</u>
PRINT	PRINT