



# COUNTY OF RIVERSIDE DEPARTMENT OF ENVIRONMENTAL HEALTH

(888)722-4234 • RIVCOEH.ORG

## INSPECTION REPORT

FACILITY NAME Wendy's #9783			DATE 09/02/2025	TIME IN 02:00 PM	TIME OUT 02:30 PM
FACILITY ADDRESS 3565 Central Ave Riverside, CA 92506-2702			FACILITY PHONE #		
PERMIT HOLDER Cotti Foods California Inc			EMAIL whoo9415@cottifoods.net		
PERMIT # PR0064735	FACILITY DESCRIPTION FF 2001-5999 SQFT Unpack	EXPIRATION DATE 05/31/2026	DISTRICT 5	SERVICE Follow Up Inspection	REINSPECTION DATE Next Routine

**General Comments:**

Re-check for exhaust and hot water. The exhaust system appears to be operating in proper order and no exhaust escaping kitchen. Hot water measured 120 degrees F.

Thank you

**Observations:**

**SIGNATURE**



PERSON IN CHARGE: Cinthy

PRINT



SPECIALIST: Richard Conant

PRINT