



COUNTY OF RIVERSIDE DEPARTMENT OF ENVIRONMENTAL HEALTH

(888)722-4234 • RIVCOEH.ORG

INSPECTION REPORT

FACILITY NAME Chick-fil-A			DATE 02/25/2026	TIME IN 01:30 AM	TIME OUT 02:00 PM
FACILITY ADDRESS 29847 Haun Rd Menifee, CA 92586-6539			FACILITY PHONE # (951) 430-2225		
PERMIT HOLDER Shane Wilkey			EMAIL shane.wilkey@cfafranchisee.com		
PERMIT # PR0089133	FACILITY DESCRIPTION FF 2001-5999 SQFT Unpack	EXPIRATION DATE 12/31/2026	DISTRICT 45	SERVICE Inspection/No Score	REINSPECTION DATE Next Routine

General Comments:

L. Le responded to a complaint regarding an Ansul system discharge at Exhaust Hoods #1 and #2. Manager Nathaniel Buttell indicated that HVAC work performed earlier that morning likely triggered the discharge at the fries stations. The facility was voluntarily closed, and staff discarded all affected food, utensils. Employees are currently working to remove the old oil from the affected fryers to begin deep-cleaning and sanitizing the units and surrounding surfaces. The Ansul system was manually reset by Service Manager Alfred Canal, and currently awaits a professional recharge today by Edison. The facility is approved to reopen when the Ansul system is fully serviced, all grease residues are removed, and final clearance from all other regulatory agencies (ex. Fire Department). Fire inspector, Iliana Gutierrez, was present during this investigation.

Observations:

SIGNATURE



PERSON IN CHARGE: John Fick

PRINT



SPECIALIST: Luan Le

PRINT