



COUNTY OF RIVERSIDE DEPARTMENT OF ENVIRONMENTAL HEALTH

(888)722-4234 • RIVCOEH.ORG

INSPECTION REPORT

FACILITY NAME Starbucks #25820			DATE 06/18/2026	TIME IN 11:00 AM	TIME OUT 12:45 PM
FACILITY ADDRESS 42500 Bob Hope Dr Ste D Rancho Mirage, CA 92270-4429			FACILITY PHONE # (206) 594-7273		
PERMIT HOLDER Starbucks Corporation			EMAIL LicenseServices@starbucks.com		
PERMIT # PR0070073	FACILITY DESCRIPTION FF 1-2000 SQFT Unpack	EXPIRATION DATE 04/30/2027	DISTRICT 26	SERVICE Inspection/No Score	REINSPECTION DATE 06/19/2026

General Comments:

Inspector M.Estock Responded a complaint of plumbing issues and the restrooms being closed inside the Starbucks facility.

At the time of the investigation, the inspector observed a plumbing work crew in the parking lot. The plumbing contractor reported that a section of 6" sewer pipe was being replaced due to root intrusion. They are currently fixing the blockage and were in coordination with the affected food facilities (Starbucks and Haus of Poke) and had asked them to limit the flow of wastewater and will ultimately need them to cease all discharge to the sewer lines to complete the repairs.

The inspector DID NOT observe any sewage overflowing from either the floor sinks and floor drains within this facility. The person in charge stated that the no back-up occurred and they were working with the plumbing contractor.

Because all discharge to the sewer will need to cease today to complete the repairs and food facilities must be able at all times to dispose of liquid waste into an approved plumbing system and a functioning sewage system, the facility will need to CLOSE at this time. The facility shall remain closed until the issue resulting in the sewage back-up in the line has been repaired. If there is any back-up inside the facility as a result of the repairs to the system, all affected surfaces must be properly cleaned and sanitized,

The facility may reopen after a re-inspection occurs, and approval to continue operation has been granted by a member of this Department. A re-inspection has been scheduled for 6-19-26. You may contact the Department sooner once the problem is resolved.

Repair the issue causing the sewage back up within the facility and properly clean and sanitize the affected areas. The Department's information bulletin on handling emergency situations including sewage back-ups can be found on the department's website.

Observations:

SIGNATURE



PERSON IN CHARGE: Manager on Duty Barret Slankard

PRINT



SPECIALIST: Mark Estock

PRINT